



UNITED BRASS WORKS, INC.
 714 S. Main St. Randleman, N.C. 27317
 Tel: 800-334-3035 Fax: 800-498-4696 www.ubw.com




**Model 34041 High Pressure
 Boiler Gauge Fixture Set
 With Ball Check**

250WSP @ 406° F

**ASME Compliant per B31.1 and
 Section One, PG 60 Appendix A18
 of ASME Boiler Code
 CRN OCO7137.2C**

**This gauge fixture set is an offset design.
 Both valves have union bonnets with blow-
 out proof stems. The union tail pieces
 incorporate an 1/8" adjustment to aid in
 alignment.**

*** Contains Lead. Not Intended for Use
 in Potable Water Systems ***



MATERIAL LIST		
No.	Description	Material
1	902 1/2"	See Valve Spec
2	908 Rod Set 10"	Steel
3	903 1/2"	See Valve Spec

***To determine proper glass
 length subtract 3/4" from the
 center-to-center dimension of
 the installed valves***

Unit Weight 6.5 lbs.